WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43581
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 25066

1. OWNER Gene Jones
MAILING ADDRESS 87 E. Fairview
Fallon, NV 89406

ADDRESS AT WELL LOCATION
1497 Del Rio
Fallon, NV 89406

2. LOCATION SE ¼ SE ¼ Sec 24 T 19 N X R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) 008-311-36 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Sand | | 0 | 11 | 11 |
| Brown Clay | | 11 | 18 | 7 |
| Brown Sand | | 18 | 33 | 15 |
| Fine Green Sand | | 33 | 45 | 12 |
| Black CLay | | 45 | 74 | 29 |
| Gray Sand | | 74 | 95 | 21 |
| Brown Clay | | 95 | 98 | 3 |
| Fine Brown Sand | | 98 | 117 | 19 |
| Brown Coarse Sand | X | 117 | 126 | 9 |

'94 JAN 10 P1:38
STATE ENGINEER

Date started 12/9/ 19 93
Date completed 12/10 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 126 Feet Depth Cased 126 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | 0 Feet | 126 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 121 |
| | | | | |
| | | | | |

Perforations:
Type perforation Well Screen
Size perforation .035
From 121 feet to 126 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 126 feet

9. WATER LEVEL
Static water level 17' 6" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date Jan 5, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627