

OFFICE USE ONLY
 Log No. 43583
 Permit No. _____
 Basin 8-106

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22775

1. OWNER Jungles Const. ADDRESS AT WELL LOCATION 3750 Alcorn
 MAILING ADDRESS 2150 Mt View

2. LOCATION SW 1/4 SW 1/4 Sec 27 T 19 N/S R 28 E Churchill County
 PERMIT NO. 8-431-09 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	8	8
Clay		8	13	5
Sand	X	13	45	32
Black Clay		45	54	9
Black silt	X	54	73	19
Gravel	X	73	85	12

8. WELL CONSTRUCTION
 Depth Drilled 85 Feet Depth Cased 85 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>10</u>	<u>0</u>	<u>80</u>
<u>6</u>	<u>80</u>	<u>85</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.75</u>	<u>12.7</u>	<u>.188</u>	<u>71</u>	<u>85</u>

Perforations:
 Type perforation Machine Slot
 Size perforation .060

From _____ feet to _____ feet
 From 76 feet to 82 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 14-8 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Contractor
 Address Box 888 Contractor
Tollan Nev.

Nevada contractor's license number issued by the State Contractor's Board 10752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed W. B. Apple
 By driller performing actual drilling on site or contractor
 Date Sept 29-93

Date started Sept 29, 1993
 Date completed Sept 29, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>35</u>		