WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43586
Permit No.
Basin 7-92B

NOTICE OF INTENT NO. 23928

1. OWNER Mike Pitts
MAILING ADDRESS 9670 North Virginia Reno, Nevada
ADDRESS AT WELL LOCATION 9670 North Virginia Reno, Nevada

2. LOCATION SW ¼ NE ¼ Sec. 8 T. 20 N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 082-101-11 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED: ☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE: ☑ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☑ Rotary ☐ RVC ☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, brown Sandy		0	27	27
Sand		27	32	5
Clay, Red		32	94	62
Gravel to 1"	✓	94	102	8
Clay, Red		102	160	58
Gravel to 3/4"		160	176	16
Clay, Red		176	210	34
Gravel ½"	✓	210	214	4
Clay, Red		214	320	106
Gravel to 3/4"		320	332	12
Clay, Red		332	354	22
Conglomerate		354	408	54
Gravel & Sand		408	416	8
Rock, Grey, Fractured		416	435	19

Date started 11-2, 1993
Date completed 11-30, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	—	4

8. WELL CONSTRUCTION
Depth Drilled 435 Feet Depth Cased 435 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	50
9⅞	50	340
6⅛	340	435

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	12.97	0.188	0	340
5	9.66	0.188	335	435

Perforations:
Type perforation Factory Mill Slot
Size perforation ⅛
From 60 feet to 80 feet
From 100 feet to 120 feet
From 140 feet to 160 feet
From 180 feet to 200 feet
From 220 feet to 435 feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 340 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name M & Kay Drilling (Contractor)
Address 2290 Pioneer Drive (Contractor)
Reno Nevada 89509
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1261
Signed [signature] (By driller performing actual drilling onsite or contractor)
Date 1/9/94

(Rev. 1-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627