

OFFICE USE ONLY
 Log No. 43598
 Permit No. **9281**
 Basin. **9281**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18989

1. OWNER Marvin Mason ADDRESS AT WELL LOCATION 10890 Red Pine Rd Reno
 MAILING ADDRESS 10890 Red Pine Rd Reno Nevada
 2. LOCATION NW 1/4 NW 1/4 Sec. 26 T. 21 S. R. 19 E Washoe County
 PERMIT NO. 80-5587 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|--------------|--------------|------|-----|-----------|
| Clay, Sandy | | 0 | 12 | 12 |
| Sand | | 12 | 29 | 16 |
| Clay, tan | | 28 | 45 | 17 |
| Small Gravel | | 45 | 48 | 3 |
| Clay, tan | | 48 | 134 | 36 |
| Gravel 1/4" | | 134 | 139 | 5 |
| Clay, tan | | 139 | 143 | 4 |
| Gravel 3/4" | | 143 | 147 | 4 |
| Clay, tan | | 147 | 158 | 11 |
| Gravel sand | | 158 | 165 | 7 |

'94 JAN 12 AM 100
 STATE LICENSE # 1000

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet
 HOLE DIAMETER (BIT SIZE)

| | From | To |
|--------------|------|-----|
| 1 7/8 Inches | 0 | 50 |
| 9 7/8 Inches | 50 | 130 |
| 6 1/2 Inches | 150 | 165 |

 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 3/8 | 12.97 | .188 | 0 | 150 |
| 5 | 9.66 | .184 | 150 | 165 |

 Perforations:
 Type perforation factor mill slot
 Size perforation 28
 From 90 feet to 150 feet
 From 150 feet to 165 feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 54
 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 54 feet to 150 feet

Date started 12-30, 1983
 Date completed 1-4, 1984

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--------|-------------------------------|--------------|
| 25 | | 2 |

9. WATER LEVEL
 Static water level 59 feet below land surface
 Artesian flow: _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name McKay Drilling Contractor
 Address 2790 Pioneer Drive Reno Nevada Contractor
 Nevada contractor's license number 14170 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1261
 Signed Steve McKay
 By driller performing actual drilling on site or contractor
 Date 1/4/84