WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43607
Permit No.
Basin 7-99

NOTICE OF INTENT NO. 25267

1. OWNER Kevin Weatherford
MAILING ADDRESS 336 K Street, Sparks, Nevada 89431
ADDRESS AT WELL LOCATION 205 Shetland Drive

2. LOCATION SE ¼ NE ¼ Sec. 16 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 078151-19 Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Sandy clay		0	80	80
Granite w/clay layers		80	157	77
Clay & consolidated sand		157	198	41
Clay w/sandy layers		198	206	8
White sandy clay		206	215	9
Hard Granite w/clay layers		215	400	185

Date started 01-18-94, 19
Date completed 02-01-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	200	4

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	400 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	400

Perforations:
Type perforation Mill Slot
Size perforation .125
From 300 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 feet
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 39 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sargent Irrigation Company (Contractor)
Address 9955 North Virginia Street (Contractor)
Reno, Nevada 89506

Nevada contractor's license number issued by the State Contractor's Board 0021246

Nevada driller's license number issued by the Division of Water Resources, the on-site driller

Signed Dan Trampe (By driller performing actual drilling on site or contractor)
Date 02-08-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627