WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43631
Permit No.
Basin 4-61

NOTICE OF INTENT NO. 18393

1. OWNER Barrick Goldstrike Mine
MAILING ADDRESS P.O. Box 29
Elko Nevada 89801

ADDRESS AT WELL LOCATION
Barrick Goldstrike Mine

2. LOCATION SE ¼ NE ¼ Sec. 30 T. 36 N/S R. 50 E Eureka County
PERMIT NO. 55/50 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PUMP CEMENT TO SURFACE FROM 670 Ft CASING				
WAS SEALED AT SURFACE AND NOT PULLED.				
CASING WAS NOT RIPPED DUE TO SLOTS IN CASING				
NOTE: hole caved below 670 Ft before it				
was ever completed.				

'94 FEB -2 A10:39

Date started October 15, 1993, 19
Date completed October 15, 1993, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 810 Feet Depth Cased 670 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	150 Feet
8-7/8 Inches		150 Feet	810 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12	33	.250	0	150
6	17	.250	0	450

Perforations:
Type perforation slots
Size perforation .125"
From 450 feet to 670 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 150
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level None feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lang Exploratory Drilling (Contractor)
Address 2286 West 1500 South (Contractor)
Salt Lake City Ut 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1829
Signed Fred Schmalfeldt (By driller performing actual drilling on site or contractor)
Date November 1, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627