WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43634
Permit No.
Basin 4-61

NOTICE OF INTENT NO. 19386

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ NW ¼ Sec 30 T 36 X N/S R 50 E EUREKA County
PERMIT NO. M/O-441 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PUMP CEMENT TO	SURFACE FROM			
980 FT. WELL CA	SING WAS SEALED			
AT THE SURFACE	SO IT WAS NOT PULLED			
CASING WAS NOT	RIPPED DUE TO			
PERFORATIONS AL	READY IN CASING			

'94 FEB -2 AM 9:39
STATE

Date started OCTOBER 14, 1993, 19
Date completed OCTOBER 14, 1993, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/4	Inches	0 Feet	35 Feet
6-1/2	Inches	35 Feet	980 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	38	.500	0	35
1-1/4	2.25	.140	0	440

Perforations:
Type perforation DRILLED
Size perforation 1/8"
From 440 feet to 980 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 420 feet to 980 feet

9. WATER LEVEL
Static water level 459 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1829
Signed Todd Schmalzle (By driller performing actual drilling on site or contractor)
Date 11/1/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627