WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 43684
Permit No.
Basin 230

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13558

1. OWNER US Ecology Inc
MAILING ADDRESS PO Box 578
Beatty Nev 89003

ADDRESS AT WELL LOCATION Same

2. LOCATION ¼ NW ¼ Sec. 35 T. 13S N/S R. 47 E. 74 Nye County
PERMIT NO. under Water (Issued by Water Resources) | Parcel No. | Well # 001 (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Monitoring
Domestic ☐ Irrigation ☐ Test ☑
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Sand + Gravel		0	21	21
Sand + Gravel		21	141	120
Sand Gravel W/Clay		141	335	194
Sand Gravel	335		339	4
Sandy Clay + Rock		339	365	26

Bentonite Plug
332.7 To 335.8 Feet

RECEIVED
DEC 13 1990
STATE ENGINEER'S OFF

Date started 2-28, 19 90
Date completed 10-10, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 16" inches Total depth 42' feet
12" inches To 365.7'
inches
Casing record Carbon Steel + Stainless
Weight per foot ..... Thickness .250

Diameter	From	To	
6" inches	0 feet	300 feet	C.S.
6" inches	300 feet	340.7 feet	S.S.
inches	feet	feet	
inches	feet	feet	
inches	feet	feet	
inches	feet	feet	

Surface seal: Yes ☑ No ☐ Type Grout
Depth of seal 332.7 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 335.8 feet to 365.7 feet
Silica Sand

Perforations:
Type perforation ~~Silica Sand~~ Stainless Steel Screen
Size perforation .010
From 340.7 feet to 360.7 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 341 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 70 °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co (Contractor)
Address RT 15 Box 643 Amargosa Val Nev 89020 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5376A
Nevada contractor's driller's number issued by the Division of Water Resources 830
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-10-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627