

Log No. 43691

Permit No. 53454

Basin 212

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 5030

PRINT OR TYPE ONLY

1. OWNER David A. Baal ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 7300 Pirate Cove Rd., Apt 1093 Rocky & Homestead
Las Vegas, Nevada 89128
 2. LOCATION SW 1/4 NE 1/4 Sec 5 T. 19 N/S R. 60 E. Clark County _____
 PERMIT NO. 53454 Issued by Water Resources Parcel No. _____ NE NE SW NE 5-19-60 Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
cemented gravel		0	38	38
sandy clay		38	70	32
cemented gravel		70	150	80
gravelly clay		150	160	10
brown clay		160	190	30
gravelly clay		190	218	28
gravel	xx	218	225	7
cemented gravel		225	235	10
gravel	xx	235	320	85
gravel	xx	320	335	15
cemented gravel		335	365	30
gravel	xxx	365	385	20
cemented gravel		385	400	15

RECEIVED
 DEC 12 1990
 Div. of Water Resources
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
 Diameter 10 inches Total depth 400 feet
 _____ inches
 _____ inches
 Casing record 8 5/8 inch to 400 ft
 Weight per foot .156 Thickness _____
 Diameter From To
12" hole inches _____ 0 feet _____ 50 feet
10" hole inches _____ 50 feet _____ 400 feet
 _____ inches _____ feet _____ feet
8 5/8 inches casing 0 feet _____ 400 feet
 _____ inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal 50 ft. feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation torch cut
 Size perforation 3/16" X 10"
 From 200 feet to 400 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 188 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4-30-90, 19_____
 Date completed 5-29-90, 19_____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	Bailed <u>40</u> G.P.M. from	<u>205</u> ft.	

BAILER TEST

G.P.M.	Draw down	feet	hours

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S. R. McKinney & Sons, Inc.
 Contractor
 Address 1042 South Main St. Las Vegas, Nevada
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 2065
 Nevada contractor's driller's number issued by the Division of Water Resources 15
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 270
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-5-90

