WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43331
Permit No.
Basin 4-G

NOTICE OF INTENT NO. 8428

1. OWNER Mt State Mineral ENTERPRISES
MAILING ADDRESS 4370 So Freemont
TUCSON ARIZ. 85714
ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ NW ¼ Sec. 33 T 33 N/S R 48 E EUREKA County
PERMIT NO. 57456 (Issued by Water Resources) Parcel No. Subdivision Name: Dumphy

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Drill out 65' of Cement + Clean out Heavy mud Develope W/ Bailer + air				
TD				
This well was Drilled & plugged. Re opened				
Top Soil		0	13	13
Rock + sand		13	84	
Sandy Clay		84	160	

93 JAN 32 P2:07
STATE ENGINEER'S OFFICE

Date started Nov 26, 1992
Date completed Nov 27, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	260

Perforations:
Type perforation FACT
Size perforation
From 180 feet to 260 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA DRILLING (Contractor)
Address 181-14 - BULLION Rd. (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 20684
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
Signed Shane Burnett (By driller performing actual drilling on site or contractor)
Date Dec 13 - 92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627