


OFFICE USE ONLY  
 Log No. 43741  
 Permit No. \_\_\_\_\_  
 Basin 4-71



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 1450

PRINT OR TYPE ONLY

1. OWNER Richard + Pam Brown ADDRESS AT WELL LOCATION 3595 Brown Lane  
 MAILING ADDRESS 3565 Brown Lane  
Winnemucca NV 89445

2. LOCATION S.W. 1/4 NE 1/4 Sec 13 T 35 N/S R 37 E Humboldt County  
 PERMIT NO. Domestic Issued by Water Resources DZ-3635 Parcel No. N/A Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Cobbles, Sand, Gravel</u>		<u>3</u>		
<u>Boulders, Bang Bangs</u>				
<u>BIT FOR BREAKFAST PXS,</u>			<u>150</u>	<u>197</u>
<u>IN AND OUT OF Small</u>				
<u>Fingered Layers of Sand</u>				
<u>AND Gravel Very Little Clay</u>				
<u>BUT TO THE BEST OF MY</u>				
<u>KNOWLEDGE 420 WAS</u>				
<u>ENCOUNTERED AT ABOUT</u>				
<u>102 FEET</u>				

FEB 19 AM :00  
 RECEIVED  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 10 7/8 inches Total depth 150 feet

Casing record 6 5/8 inches

Weight per foot 12 Thickness 198

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 1</u> feet	<u>150</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Grout

Depth of seal 48 feet

Gravel packed: Yes  No

Gravel packed from 48 feet to 150 feet

Perforations:  
 Type perforation SAW CUT  
 Size perforation 3/32  
 From 110 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 11 21 1990  
 Date completed 11 23 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 92 feet below land surface

Flow AIRLIFT G.P.M. 20+ P.S.I.

Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fred Anderson Contractor

Address 10760 Grass Valley Rd Contractor

Nevada contractor's license number issued by the State Contractor's Board 021467

Nevada contractor's driller's number issued by the Division of Water Resources 1375

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date 11 - 24 - 90