

OFFICE USE ONLY
 Log No. 43750
 Permit No. _____
 Basin 6-88

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24462

1. OWNER Rick & Corrie Walden ADDRESS AT WELL LOCATION 22879 Carrigge Dr.
 MAILING ADDRESS 2675 Nicholatte Dr. Pleasant Valley, Reno NV 89503
 Reno NV 89503
 2. LOCATION SE 1/4 SE 1/4 Sec. 7 T. 17 N. S. R. 20 E. Washoe County
 PERMIT NO. 050-114-07 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------------------------------|--------------|------|-----|-----------|
| Overburden | | 0 | 2 | 2 |
| Brown Sands | | 2 | 8 | 6 |
| Course Gravels and loose cobbles | | 8 | 45 | 37 |
| Sandy Clay | | 45 | 55 | 10 |
| Loose cobbles | | 55 | 83 | 28 |
| HARD obsidian gravels | XXX | 83 | 120 | 37 |

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 1/4 Inches To 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u> | <u>13.03</u> | <u>.188</u> | <u>0</u> | <u>120</u> |

Perforations:
 Type perforation Mill Slot
 Size perforation 3/32
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 120' feet

9. WATER LEVEL
 Static water level 2' feet below land surface
 Artesian flow NO G.P.M. 18 P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H Pump Co. Contractor
 Address 5551 Hwy 50 E. #3 Contractor
Carson City NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael Hoak
 By driller performing actual drilling on site or contractor
 Date 10-29-93

Date started 10-27, 1993
 Date completed 10-29, 1993

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | | |
|---|-------------------------------|--------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| <u>18</u> | <u>35</u> | <u>3 1/2</u> | |

'93 NOV -3 A9 104
 RECEIVED
 STATE ENGINEERS OFFICE