

Work Permit # 4859

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 43759
Permit No.
Basin 6-89

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24460

1. OWNER Jack Novak
MAILING ADDRESS 1990 Lakeshore Dr. Carson City NV 89704
ADDRESS AT WELL LOCATION 1990 Lakeshore Dr. Carson City NV 89704
NEW WASHOE CITY
2. LOCATION NW 1/4 NW 1/4 Sec 30 T 17 N S R 20 E Washoe County
PERMIT NO. WASHOE 004859 50-368-10 New Washoe City
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Brown Sands		3	10	7
Coarse Sands & Gravels		10	64	44
Silty Gray Sands		64	84	30
Brown Clay		84	109	25
Gray Silt		109	118	9
Coarse Sands	XX	118	145	27

8. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet
HOLE DIAMETER (BIT SIZE)
From 10 3/4 Inches To 145 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.14	.188	0	145

Perforations:
Type perforation Mill slot
Size perforation 3X32
From 125 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal: Yes No Seal Type:
Depth of Seal 50 Ft. Neat Cement
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 50 feet to 145 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature Cold °F Quality Good

Date started 10-21 1993
Date completed 10-22 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	20	30'	3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.H. Pump Co. Contractor
Address 5551 Hwy 50 E #3 Contractor
Carson City NV 89702
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Haek
By driller performing actual drilling on site or contractor
Date 10-22-93