

OFFICE USE ONLY
 Log No. 43764
 Permit No. _____
 Basin 93

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

LEAD

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23786

1. OWNER Gerald Voivod ADDRESS AT WELL LOCATION 1460 Roth Rd Half Mile Rd
 MAILING ADDRESS 2445 Antelope Valley Rd Parcel # 2
Reno, Nv 89506

2. LOCATION NE 1/4 NW 1/4 Sec. 27 T. 22 N/S R. 19 E Washoe County
 PERMIT NO. 79-450-28 Antelope Valley Red Rock East #101 parcel 2
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan yellow white brown D.G. sands & gravels		0	18	18
Reddish brown clay with brown tan & white D.G. sands		18	39	21
Green brown white granite decomposed		39	115	76
Green white semi decomposed granite hard & fractured		115	208	93
Black white & green granite hard few fractures		208	403	195
T.D. 403 ft				

8. WELL CONSTRUCTION
 Depth Drilled 403 Feet Depth Cased 403 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10 5/8	0	56
8 1/2	56	220
8	220	403

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 2	403

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 383 feet to 403 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 53 feet to 403 feet

9. WATER LEVEL
 Static water level 320 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 10/28/93, 19_____
 Date completed 11/2/93, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L
 Contractor
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller
 Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 11/4/93