

OFFICE USE ONLY
 Log No. 43765
 Permit No. _____
 Basin 7-92a

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 21845

1. OWNER JOE MOONEYHAM ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 60681 13990 Red Rock Road
Reno, NV 89506 Reno, NV 89506
 2. LOCATION NW 1/4 SW 1/4 Sec 32 T. 22N N/S R. 19 E Washoe County
 PERMIT NO. 079-342-04 Red Rock Estates #22
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown clay with smaller boulders & gravels		1	18	17
Sandy brown clay		18	69	48
Brown clay with decomposed granite mixed		69	111	42
Soft zone (NO WATER)		111	114	3
Brown clay		114	213	99
Brown sandy clay		213	316	103
Soft zone (NO WATER)		316	318	2
Granite sands with brown clay		318	369	51
Soft zone	X	369	371	2
Brown sandy clay		371	389	18
Soft zone	X	389	396	7
Brown clay		396	410	14
Fine brown sand with clay streaks		410	425	15

8. WELL CONSTRUCTION
 Depth Drilled 425 Feet Depth Cased 425 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches 0 Feet 50 Feet
 To 6 5/8 Inches 50 Feet 425 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	425

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 360 feet to 420 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 425 feet

9. WATER LEVEL
 Static water level 298 feet below land surface
 Artesian flow 18 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370
 Contractor
Reno, NV 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller.
 Signed Wayne Drilling, Inc.
 by driller performing actual drilling on site or contractor
 Date October 12, 1993

Date started 10-4-93, 19____
 Date completed 10-7-93, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
<u>GPM</u>			
	Draw Down (Feet Below Static)		Time (Hours)