

OFFICE USE ONLY  
Log No. 43783  
Permit No. \_\_\_\_\_  
Basin B-101

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23444

1. OWNER Clayson Trigero ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 2325 Reno Hwy 2325 Reno Hwy  
Fallon, NV 89406 Fallon, NV 89406

2. LOCATION SW 1/4 SE 1/4 Sec. 26 T. 19 N/SR 28 E Churchill County \_\_\_\_\_  
PERMIT NO. 08-361-04 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Coarse Brown Sand		0	38	38
Fine Green Sand		38	52	14
Coarse Gray Sand		52	55	3
Gray Sandy Clay		55	60	5
Gray Coarse Sand		60	78	18
Brown Clay		78	82	4
Fine Brown Sand		82	95	13
Greenish Brown Clay		95	110	15
Green Sandy Clay		110	129	19
Gray Clay		129	135	6
Fine Gray Sand		135	140	5
Coarse & Fine Gray Sand		140	175	35
Brown Sandy Clay		175	178	3
Coarse Brown Sand	X	178	200	22

8. WELL CONSTRUCTION  
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 200 Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	195

Perforations:  
Type perforation Well Screen Steel  
Size perforation .035  
From 195 feet to 200 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 100  Cement Grout  
Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
From 100 feet to 200 feet

9. WATER LEVEL  
Static water level 22 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Parsons Drilling, Inc. Contractor  
Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
Nevada contractor's license number 29064 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
Signed Wynn Pearson By driller performing actual drilling on site or contractor  
Date 10/30/93

Date started October 15, 1993  
Date completed October 15, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

93 NOV -8 P1:46  
STATE ENGINEERS OFFICE