

OFFICE USE ONLY
 Log No. 43794
 Permit No. 8-103
 Basin 8-103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25323

1. OWNER Stevenes Const ADDRESS AT WELL LOCATION 7 Dana Ct.
 MAILING ADDRESS Carson City

2. LOCATION NE 1/4 NE 1/4 Sec 31 T 16 S R 21 E Lyon County
 PERMIT NO. 19-063-02 Parcel No. Sierra View Estates Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Brown hard clay		3	27	24
Sandy clay		27	43	16
Clay seams w/ imbedded gravel		43	68	25
Large gravels w/ small clay seams	xxx	68	100	32

'93 OCT -4 AM 123
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 100' Feet Depth Cased 100' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 100' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.23</u>	<u>.188</u>	<u>0</u>	<u>100</u>

Perforations:
 Type perforation Mill shot
 Size perforation 3 x 3/8 2
 From 80' feet to 100' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 51 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 51 feet to 100' feet

9. WATER LEVEL
 Static water level 30 feet below land surface
 Artesian flow _____ G.P.M. 18 P.S.I.
 Water temperature Cold F Quality Good

Date started 9-30 1997
 Date completed 10-3 1997

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>18</u>	<u>30</u>	<u>2</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO.
 Address 5551 Hwy 50 East #3 Carson City, Nevada 897
703-0459 - 883-401
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
 Signed Quanton R. Butts
 By driller performing actual drilling on site or contractor
 Date 9/27/93