WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 43796
Permit No.
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15200

1. OWNER Elaine Fresonke
MAILING ADDRESS 4646 Geary St #1
San Francisco, Calif. 94118

ADDRESS AT WELL LOCATION 144 Prospector

2. LOCATION SE ¼ NE ¼ Sec. 30 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. (Issued by Water Resources) UNIT 3 Lot #29 (Parcel No.) MARK TWAIN ESTATES (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	15	
CLAY & SAND		15	30	
CLAY SAND & GRAVEL		30	35	
~~CLAY & SAND~~		35	70	
CLAY & SAND		70	150	
CLAY SAND & GRAVEL	X	150	155	
CLAY & SAND	X	155	165	
CLAY SAND & GRAVEL	X	165	170	
CLAY & SAND	X	170	195	
SAND & GRAVELS	XX	195	225	

RECEIVED
JAN 30 A9:59
STATE ENGINEER'S OFFICE

Date started 10-30, 1990
Date completed 11-3, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR	20+		2½ hrs.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 225 feet
..... inches
..... inches
Casing record ASTM 53A 20' x 188 x 6"
Weight per foot ..... Thickness .188

Diameter	From	To
6 inches	0 feet	225 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Fine grout
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 225 feet to 50 feet

Perforations:
Type perforation Factory PerF
Size perforation 3" x 5/32"
From 225 feet to 205 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 140 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Rauchack Drilling Inc. (Contractor)
Address 2668 Fuller Minden, Nv. 89423 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board #021268
Nevada contractor's driller's number issued by the Division of Water Resources #1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller #495
Signed Michael Allen
By driller performing actual drilling on site or contractor
Date 11-14-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627