

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 43805
 Permit No. _____
 Basin B-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24309

1. OWNER Nevada Johnson ADDRESS AT WELL LOCATION 1360 Creek Dr.
 MAILING ADDRESS Gardenerville N.V. Fish Springs N.V.

2. LOCATION N.W. 1/4 N.E. 1/4 Sec 5 T. 12 @ S R. 21 E. Douglas County
 PERMIT NO. 35-140-24 Parcel No. _____ Subdivision Name Fish Springs

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>Cobbles & gravel</u>		<u>12</u>	<u>30</u>	<u>18</u>
<u>Sandy clay w gravel</u>		<u>30</u>	<u>43</u>	<u>13</u>
<u>Cobbles w sandy clay</u>		<u>43</u>	<u>50</u>	<u>7</u>
<u>Sandy clay w gravel</u>		<u>50</u>	<u>83</u>	<u>33</u>
<u>gravel w sand</u>		<u>83</u>	<u>90</u>	<u>7</u>
<u>gravel w sandy clay</u>		<u>90</u>	<u>98</u>	<u>8</u>
<u>Sandy clay some gravel</u>		<u>98</u>	<u>115</u>	<u>17</u>
<u>gravel w short sandy clay stalks</u>		<u>115</u>	<u>129</u>	<u>14</u>
<u>Sandy clay some gravel</u>		<u>129</u>	<u>134</u>	<u>5</u>
<u>gravel w short clay stalks</u>		<u>134</u>	<u>160</u>	<u>26</u>

8. WELL CONSTRUCTION
 Depth Drilled 160' Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 5/8 Inches _____ Feet 160' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>160'</u>

Perforations:
 Type perforation Factory slotted
 Size perforation 3 x 3/32
 From 140' feet to 160' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100' feet to 160' feet

9. WATER LEVEL
 Static water level 27 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDGO Exploration Inc. Contractor
 Address 7780 Curry Rd. Contractor
Fallon N.V. 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Leard W. Phinnell
 By driller performing actual drilling on site or contractor
 Date 10-12-93

Date started 10-8, 1993
 Date completed 10-12, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25'</u>	<u>—</u>	<u>1.50</u>

'93 OCT 22 AM 05B
 STATE ENGINEERS OFFICE