WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 43813
Permit No.
Basin 10-137a

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER N.A. Degerstrom
MAILING ADDRESS N. 3303 Sullivan Rd Spokane, Wa. 99216
ADDRESS AT WELL LOCATION Manhattan

2. LOCATION SE ¼ NE ¼ Sec. 22 T. 8 N/S R. 43 E. mdbm Nye County
PERMIT NO. 53102 (Issued by Water Resources) Parcel No. S 14°, 42 min 55 Seconds East 2784.93 feet (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Decomposed Skist		0	3	3
Brown hard shale		3	97	95
Black hard sh w/ Quartz		97	147	50
Black " Sh w/ Fractures And Quartz (lost Circu.)		147	152	5
Black Shale w Quartz		152	320	168

'90 OCT 17 P3:24
STATE ENGINEERS OFFICE

Date started ....., 19....
Date completed July 11, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
No Test			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 17" inches Total depth 320 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
8 3/8" inches	+2 feet	320 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 100' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 320 feet

Perforations:
Type perforation Factory 1/8 x 4
Size perforation
From 200 feet to 320 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 72 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO Exploration Inc (Contractor)
Address 7780 Curry Rd Fallon Nv (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed [signature] By driller performing actual drilling on site or contractor
Date 10-10-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627