WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43852
Permit No.
Basin

NOTICE OF INTENT NO. 11812

1. OWNER Sigmund L. Drellack
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1860 Horn RD

2. LOCATION SW ¼ NW ¼ Sec. 17 T. 20-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 87 Unit F (Parcel No.) Cal-Vegas Acres (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
White Clay		4	22	18
Grey Clay		22	44	22
Caliche Formation		44	50	6
Light Brown Clay	x	50	82	32
Reddish Brown Clay	x	82	126	44
Brown Clay	x	126	160	34

RECEIVED
FEB 04 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started January 14, 1994
Date completed January 17, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18 lbs.	.188	0	160

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed (By driller performing actual drilling on site or contractor)
Date January 20 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627