WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43856
Permit No.
Basin

NOTICE OF INTENT NO. 12790

1. OWNER TIM BELCASTRO
MAILING ADDRESS
ADDRESS AT WELL LOCATION: LOT 156 WHIRLWIND PAHRUMP NV 89041

2. LOCATION SW ¼ SW ¼ Sec. 1 T 21S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) Parcel No. 44-092-23 Subdivision Name MANKO

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	7	7
CALICHIE		7	11	4
CLAY		11	15	4
CALICHIE		15	17	2
CLAY		17	34	17
CALICHIE		34	41	7
CLAY		41	50	9
CALICHIE	WB	50	53	3
CLAY		53	60	7
CALICHIE	WB	60	62	2
CLAY		62	73	11
CALICHIE	WB	73	75	2
CLAY		75	86	11
CALICHIE	WB	86	89	3
CLAY		89	98	9
CALICHIE	WB	98	101	3
CLAY		101	107	6
CALICHIE	WB	107	112	5
CLAY		112	124	12
CALICHIE	WB	124	126	2
CLAY		126	129	3
CALICHIE	WB	129	132	3
CLAY		132	135	3
CALICHIE	WB	135	138	3
CLAY		138	140	2
		140		140

Date started 1-3-94, 19
Date completed 1-8-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
FEB 09 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches	0 Feet	140 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout X ☐ Concrete Grout

Gravel Packed: ☐ Yes X ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 48 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80350 (Contractor)
PAHRUMP NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 1-25-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627