WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43857
Permit No. 58053
Basin 162

NOTICE OF INTENT NO. 12484

1. OWNER Blue Horizon Investments
MAILING ADDRESS
ADDRESS AT WELL LOCATION Pahrump Valley & Manse

2. LOCATION NE ¼ NE ¼ Sec. 10 T. 21S N/S R. 53 E. Nye County
PERMIT NO. 58053 (Issued by Water Resources) 44-231-11 (Parcel No.) Plantation Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Calichie		4	6	2
Clay		6	30	24
Calichie		30	34	4
Clay		34	55	21
Calichie		55	59	4
Clay		59	63	4
Calichie	WB	63	66	3
Clay		66	85	19
Calichie	WB	85	87	2
Clay		87	115	28
Calichie	WB	115	118	3
Clay		118	131	13
Calichie	WB	131	133	2
Clay		133	144	11
Calichie	WB	144	151	7
Clay		151	163	12
Calichie	WB	163	179	16
Clay		179	191	12
Calichie	WB	191	196	5
Clay		196	200	4

Date started 12/20, 19 93
Date completed 12/23, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
FEB 09 1994
Div. of Water Resources
Branch Office Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	Inches	From Feet	To Feet
	12¼	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.44	.188	0	200

Perforations:
Type perforation Factory Saw cut
Size perforation 1/8 x 3
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 1/25/94

II

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627