WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45873
Permit No.
Basin 278

NOTICE OF INTENT NO. 19841

1. OWNER Equinox Resources
MAILING ADDRESS 5301 Longley Lane Suite 1-A
Reno, NV 89511

ADDRESS AT WELL LOCATION 40 miles west of Lovelock, Nevada

2. LOCATION NW ¼ NW ¼ Sec. 19 T. 34 N/S R. 30 E. Pershing County
PERMIT NO. 55516 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium - fine - med		0		
sand & Gravel			24	24
Volcanic Tuffs &		24		
minor pyroclastics			67	43
Water Bearing Fracture	x	67	68	1
Volcanic Tuffs &		68		
minor pyroclastics			73	5
Oxidized Fracture		73	74	1
Volcanic Tuffs &		74		
minor pyroclastics			199	125
clay rich epiclastic		199		
unit			215	16

94 MAR 14 P 1:51
STATE ENGINEER'S OFFICE

Date started September 14, 19 93
Date completed September 17, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	160	6

8. WELL CONSTRUCTION
Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	215 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	16.94	.188	+2	215

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½ 6 rows
From 50 feet to 206 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 215 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date March 4, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627