

Corrected

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 43886 43886
 Permit No. _____
 Basis CA-056
 NOTICE OF INTENT NO. 18222

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Lander County Sewer & Water Dist #2 ADDRESS AT WELL LOCATION approx. 2 miles W-NW of Austin
 MAILING ADDRESS P.O. Box 144
Austin, NV 89310
 2. LOCATION SE 1/4 SE 1/4 Sec 15 T 19 N/S R 43 E Lander County
 PERMIT NO. 59044T Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt.		0	18	18
Coarse sand w/silt		18	57	39
Coarse sand & gravel w/clay stringers, some suspended cobbles		57	119	62
Clay		119	126	7
Coarse sand & gravel w/stringers of clay and cemented sand, some cobbles		126	380	254

8. WELL CONSTRUCTION
 Depth Drilled 380 Feet Depth Cased 362 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
26 Inches 0 Feet 50 Feet
20 Inches 50 Feet 380 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	54.41	.250	0	50
12	33.38	.250	+2	141
10	28.04	.250	302	312
10	28.04	.250	352	362

 Perforations:
 Type perforation Roscoe Moss full flow
 Size perforation 1/8 slot louvered
 From 12" 141 feet to 241 feet
 From 10" 242 feet to 302 feet
 From 10" 312 feet to 362 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50' feet to 362 feet

94 FEB 14 P 2:16
 RECEIVED
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level 103.40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started January 10, 1994
 Date completed January 17, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
600	145.64	5

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address P.O. Box 590 Contractor
Winnemucca, NV 89446
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
 Signed C. E. Geph
 By driller performing actual drilling on site or contractor
 Date 2-9-94

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 43006
 Permit No. 04-056
 Basin 04-056
 NOTICE OF INTENT NO. 18222

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Lander County Sewer & Water Dist. #2 ADDRESS AT WELL LOCATION Approx. 2 miles W-NW of Austin
 MAILING ADDRESS P.O. Box 144
Austin, NV 89310

2. LOCATION SE 1/4 SE 1/4 Sec. 15 T. 19 N. S. R. 43 E Lander County
 PERMIT NO. 59044T Issued by Water Resources Parcel No. NA Subdivision Name NA

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt		0	18	18
Coarse sand w/ silt		18	57	39
Coarse sand & gravel w/clay stringers, some suspended cobbles		57	119	62
Clay		119	126	7
Coarse sand & gravel w/stringers of clay & cemented sand, some cobbles		126	380	254

8. WELL CONSTRUCTION
 Depth Drilled 380 Feet Depth Cased 362 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
26	0	50
20	50	380

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	54.41	.250	0	50
12	33.38	.250	+2	141
10	28.04	.250	302	312
10	28.04	.250	352	362

Perforations:
 Type perforation Roscoe Moss full flow
 Size perforation .080 louvered casing

From	To	feet to
12"	141	241
10"	242	302
10"	312	352

Surface Seal: Yes No Seal Type:
 Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 362 feet

'94 MAR -3 AIO:31
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level 103.40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address P.O. Box 590 Contractor
Winnemucca, NV 89446
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date February 21, 1994

Date started January 10, 1994
 Date completed January 17, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	1200	187' & still dropping	4 hrs
	600	145' & still coming up	2 hrs

*actual pumping level from top of ground.