

OFFICE USE ONLY  
 Log No. 43943  
 Permit No. 06-083  
 Basin

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24984

1. OWNER Lee Roy Schiler ADDRESS AT WELL LOCATION 49 Lockwood Road  
MAILING ADDRESS P.O. BOX 6328 Sparks, Nevada 89432  
Auburn, CA  
 2. LOCATION SE 1/4 SE 1/4 Sec. 17 T. 19 N/S R. 21 E. Washoe County  
 PERMIT NO. N/A 084-070-18 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay & gravel		0	6	
Gravel & boulders		6	26	
Green & black volcanic		26	78	
Gray clay streaks with green & black volcanic rock		78	110	
Pink clay		110	131	
Red clay		131	148	
Red rock		148	189	
Multi. colored vol. rock		189	460	

8. WELL CONSTRUCTION  
 Depth Drilled 460 Feet Depth Cased 460 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
9 7/8 Inches 0 Feet 200 Feet  
6 1/8 Inches 200 Feet 460 Feet  
 Inches Feet Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	-5	200
5 9/16	14	.258	187	460

Perforations:  
 Type perforation Mill slot  
 Size perforation 1/8 X 3  
 From 140 feet to 200 feet  
 From 334 feet to 376 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 100+  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 200 feet

9. WATER LEVEL  
 Static water level -0- feet below land surface  
 Artesian flow 2 G.P.M. minimal P.S.I.  
 Water temperature warm °F Quality fair

Date started 12-29-93, 19\_\_\_\_  
 Date completed 1-10-94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	10	450	2

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EMDLCO Contractor  
 Address P.O. Box 8056 Contractor  
Reno, Nevada 89507  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418  
 Signed Bruce Mills  
 By driller performing actual drilling on site or contractor  
 Date 1-10-94