WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

ØYCDB

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43944
Permit No.
Basin 6-85

NOTICE OF INTENT NO. 20712

1. OWNER WAYNE & PATRICIA PATERSON
MAILING ADDRESS 1636 Noreen Dr.
Sparks, NV 89434

ADDRESS AT WELL LOCATION 7325 Patrina Way
Sparks, NV 89436

2. LOCATION ~~NE~~ SE ¼ ~~SW~~ ~~NW~~ ¼ Sec. ~~34~~ T ~~22N~~ 20N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 083-440-56 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	3	2
Brown clay with gravel & sand		3	18	15
Soft zone (NO WATER)		18	20	2
Brown clay		20	44	24
Boulder		44	46	2
Brown clay		46	81	35
Weatered granite some clay streaks		81	109	28
Green granite		109	195	86
Fracture (NO WATER)		195	196	1
Green granite		196	232	36
Frature	X	232	233	1
Green granite		233	268	35
Fracture granite	X	268	273	5
Hard green granite		273	275	2

Date started 3-3-94, 19
Date completed 3-4-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	275	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	275

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 230 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 275 feet

9. WATER LEVEL
Static water level 215 feet below land surface
Artesian flow G.P.M. 17 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Edward J. [signature] (By driller performing actual drilling on site or contractor)
Date March 9, 1994

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627