CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 43958
Permit No. 42633
Basin 213

OWNER KELSAEY, HILBIG, RICHARD & SUZANNE ADDRESS

2. LOCATION SE ¼ NE ¼ Sec. 4 T. 26 S N/S R. 64 E. CLARK County
PERMIT NO. 42633

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ALLUVIAL | | 0 | 20 | |
| MULTI-COLORED ROCK | | 20 | 110 | |
| WATER 70' TO 75' | | | | |

RECEIVED FEB 19 1982 Div. of Water Resources Branch Office — Las Vegas, Nev.

Date started 1-10, 1982
Date completed 1-15, 1982

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10 3/4 inches Total depth 110 feet
Casing record 110' — 6 5/8"
Weight per foot Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | #2 feet | 110 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 110' feet

Perforations:
Type perforation MACHINE
Size perforation 1/8 X 2 1/2"
From 68 feet to 110' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 60' Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name M.D. BRINEA
Address HENDERSON, NEV.
Nevada contractor's license number 6294 A
Nevada driller's license number 693
Signed M.D. Brinea
Date 2-17-82

USE ADDITIONAL SHEETS IF NECESSARY

O-627