

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12619

1. OWNER John J & Donna Holmes ADDRESS AT WELL LOCATION 600 Theobald
 MAILING ADDRESS 600 Theobald Reno, Nevada Rm 40 NV

2. LOCATION NE 1/4 SE 1/4 Sec 4 T 17 N 8 R 20 E Washoe County
 PERMIT NO. 017-342-24 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy soil		0	2	2
sandy clay		2	9	7
cobbles & gravel		9	11	2
Sandy clay with interbedded cobbles & gravel	X	11	46	
gravel & cobbles with interbedded clay		46	60	
Yellow clay with interbedded cobbles & gravel	X	60	120	

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 120
10" Inches Feet
 Inches Feet
 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>120</u>

Perforations:
 Type perforation mill cuts
 Size perforation 1/2 x 2 1/2

From _____ feet to _____ feet
 From 100 feet to 118 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 120 feet

9. WATER LEVEL
 Static water level 25.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 72.5 °F Quality OK

Date started 1-3 1994
 Date completed 1-6 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>UNKNOWN</u>	<u>2 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DRASIS DRILLING INC. Contractor
 Address PO Box 21421 Contractor
CARSON CITY NEVADA 89721
 Nevada contractor's license number issued by the State Contractor's Board 0023129
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
 Signed J. Anzures
 By driller performing actual drilling on site or contractor
 Date 1-9-94