

OFFICE USE ONLY
 Log No. 43976
 Permit No. 88-101
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25078

1. OWNER Harold C. Diezel ADDRESS AT WELL LOCATION
 MAILING ADDRESS 2161 W. Williams #27 3909 London Circle
Fallon, Nevada 89406 Fallon, Nevada 89406
 2. LOCATION SW 1/4 NW 1/4 Sec. 15 T. 18 N/S R. 28 E Churchill County
 PERMIT NO. 06-472-28 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	10	10
Brown Coarse Sand		10	22	12
Fine Green SAND		22	30	8
Black Clay		30	32	2
Black Sand		32	38	6
Grey Sand		38	42	4
Green Sandy Clay		42	55	13
Green SAND		55	59	4
Brown SAND	X	59	75	16

8. WELL CONSTRUCTION
 Depth Drilled 75 Feet Depth Cased 75 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 75 Feet
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	16.94	.188	0	70

Perforations:
 Type perforation Well Screen
 Size perforation .035
 From 70 feet to 75 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 70 feet

9. WATER LEVEL
 Static water level 6 feet below land surface
 Artesian flow G.P.M. P.S.I.
 Water temperature °F Quality

Date started January 28, 1994
 Date completed January 28, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name PARSONS DRILLING, INC. Contractor
 Address P.O. BOX 1265 Contractor
FALLON, NEVADA 89407
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
 Signed Wayne Stevens
 By driller performing actual drilling on site or contractor
 Date 2/9/94