WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43991
Permit No.
Basin 02-101

NOTICE OF INTENT NO. 25075

1. OWNER Bill Gunn
MAILING ADDRESS 465 Lewis Lane
Fallon, Nevada 89406

ADDRESS AT WELL LOCATION
465 Lewis Lane
Fallon, Nevada 89406

2. LOCATION NW ¼ SE ¼ Sec. 28 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. ____ Issued by Water Resources | 24-175-9 Parcel No. | Lewis Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Brown Sand		0	25	25
Fine Brown SAnd		25	38	13
Brown fine & Coarse Sand		38	43	5
Green Coarse Sand		43	50	7
Grey Clay Sand		50	58	8
Grey Fine Sand		58	75	17
Grey & Brown Fine Sand		75	95	20
Coarse Brown Sand		95	98	3
Fine Green SAnd		98	110	12
Fine Grey SAnd		110	115	5
Grey Sandy Clay		115	140	25
Grey Sand		140	150	10
Brown Fine Sand		150	160	10
Brown Fine & Coarse SAnd	X	160	170	10

Date started Jan 17, 1994
Date completed Jan 18, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	170 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	165

Perforations:
Type perforation Well Screen
Size perforation .035
From 165 feet to 170 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 170 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. Contractor
Address P.O. BOX 1265 Contractor
FALLON, NEVADA 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons
By driller performing actual drilling on site or contractor
Date 2/9/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627