

OFFICE USE ONLY  
 Log No. 43997  
 Permit No. 8-101  
 Basin. 8-101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Geo. Gill ADDRESS AT WELL LOCATION 4625 Alcorn  
 MAILING ADDRESS 4625 Alcorn  
 2. LOCATION NE 1/4 NW 1/4 Sec. 33 T. 19 N/S R. 28 E Churchill County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand	✓	0	40	40
Grey Sand	✓	40	60	20
Brown Gravel	✓	60	75	15
Red Silt	✓	75	87	12
Black Silt	✓	87	107	30
Black Sandy Clay	✓	107	127	20
Black Sand	✓	127	150	33
Black Silt	✓	150	154	4
Brown Sand	✓	154	172	18

94 FEB 17 1994  
STATE OF NEVADA

8. WELL CONSTRUCTION  
 Depth Drilled 172 Feet Depth Cased 172 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 50 Feet  
6 Inches 50 Feet 172 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>±1</u>	<u>172</u>

Perforations:  
 Type perforation Machine Slot  
 Size perforation 3/16"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 164 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 19 8 1/2 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Contractor  
 Address Box 888 Fallon Contractor  
 Nevada contractor's license number 11752 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date Feb 14 - 94

Date started Feb 11, 1994  
 Date completed Feb 12, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>		<u>1</u>