WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44025
Permit No.
Basin 8-104

1. OWNER American Gen Development
MAILING ADDRESS 2301 Arrowhead Dr. Carson City NV. 89702
NOTICE OF INTENT NO. 25295
ADDRESS AT WELL LOCATION 3632 Silverado St. Carson City NV. 89706

2. LOCATION SW ¼ SW ¼ Sec. 6 T. 14 N/S R. 20 E/W Douglas County
PERMIT NO. Issued by Water Resources
13-101-05 Parcel No.
Jack Valley Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	6
Hardpack Clays With Gravels		6	24	18
DG Sands		24	73	49
Brown Clays		73	136	63
DG Sands w/clay Seems		136	175	39
Gummy Brown Clay		175	190	15
Loose DG Sands Large Gravels	XXX	190	220	30

Date started 2-16, 1994
Date completed 2-19, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	45	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220

Perforations:
Type perforation Mill Slot
Size perforation 3/32
From 200' feet to 220' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 220' feet

9. WATER LEVEL
Static water level 80' feet below land surface
Artesian flow G.P.M. 30 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & N PUMP CO. 5501 Hwy. Contractor
Address Carson City, Nevada Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael J Hack
By driller performing actual drilling on site or contractor
Date 2-19-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627