

OFFICE USE ONLY

Log No. 71027  
 Permit No. 8-105  
 Basin 8-105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24585

1. OWNER BOB MURRAY CONSTRUCTION ADDRESS AT WELL LOCATION 1335 Berning Way  
 MAILING ADDRESS Gardenerville N.V. Gardenerville

2. LOCATION SE 1/4 NE 1/4 Sec. 1 T. 12 S R. 19 E Douglas County  
 PERMIT NO. 19-080-09 Parcel No. MATT'SVILLE LN Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MAD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sand		3	17	14
gravel		17	60	43
Sandy clay w/ gravel		60	68	8
gravel w/ short clay streaks	X	68	102	34
grey sand some gravel		102	127	25
grey sandy clay		127	131	4
gravel w/ short clay streaks	XX	131	171	44

'94 FEB 16 AIO:32  
 STATE ENGINEERS OFF

8. WELL CONSTRUCTION  
 Depth Drilled 0 Feet Depth Cased 171 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 171  
10 5/8 Inches 0 Feet 171 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>171</u>

Perforations:  
 Type perforation Factory Slotted TIC  
 Size perforation 3 x 3/32  
 From 151 feet to 171 feet  
 From 141 feet to 151 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 100'  
 Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 100 feet to 171 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow 1 G.P.M. 1 P.S.I.  
 Water temperature 50.1 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDCO Exploration INC. Contractor  
 Address 7780 Curry Rd. Contractor  
Fallon NV 89406  
 Nevada contractor's license number issued by the State Contractor's Board 22673  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535  
 Signed Harold W. [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2-11-94

Date started 2-4, 1994  
 Date completed 2-11, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>1</u>