WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 440303
Permit No.
Basin 84-105

NOTICE OF INTENT NO. 24586

1. OWNER LEHMAN + SONS BUILDERS
MAILING ADDRESS GARDNERVILLE
ADDRESS AT WELL LOCATION 1982 SHEEPCAMP RD GARDNERVILLE

2. LOCATION SE ¼ SE ¼ Sec. 1 T. 12 N/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) | 23-190-31 (Parcel No.) | EAST VALLEY (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other M-D

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY W/COBBLES		0	6	6
CEMENTED GRAVEL		6	65	59
SANDY CLAY W/GRAVEL		65	102	37
CEMENTED GRAVEL		102	119	17
SANDY CLAY W/GRAVEL		119	168	49
SANDY CLAY		168	179	11
SANDY CLAY W/GRAVEL		179	219	40
SANDY CLAY		219	239	20
CLAY		239	266	27
SANDY CLAY		266	287	21
SAND		287	288	1
SANDY CLAY W/GRAVEL		288	299	11
SAND + GRAVEL	✓	299	308	9
SANDY CLAY W/GRAVEL		308	310	2

'94 MAR 16 A10:00 STATE ENGINEER'S OFFICE

Date started 3-7, 1994
Date completed 3-14, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	15+	—	1

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 310 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	310 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	310

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 290 feet to 310 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 310 feet

9. WATER LEVEL
Static water level 205 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. (Contractor)
Address 7780 CURRY RD (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1736
Signed Patrick J. Moore (By driller performing actual drilling on site or contractor)
Date 3-14-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627