WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44040
Permit No.
Basin 08-105

NOTICE OF INTENT NO. 24577

1. OWNER GLEN OWEN
MAILING ADDRESS GARDNERVILLE
ADDRESS AT WELL LOCATION 2846 ROMERO MINDEN

2. LOCATION SE ¼ SW ¼ Sec. 26 T. 14 (N)/S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 21-240-32 (Parcel No.) JOHNSON LANE (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cement		166	170	4
Brn. sandy clay		170	185	15
Gray sandy clay		185	290	185
Gray sandy clay w/gravel		290	310	20
Gray clay		310	314	4
Fractured Basalt		314	316	2
Gray sandy clay		316	330	14
Gray Dyerite fract	✓	330	335	5
Brn. clay		335	338	3
Fractured Basalt	✓	338	350	12
multi color clay yellow Brn. Gray		350	356	6
Gray clay w/course sand	✓	356	362	8
Basalt some fractures	✓	362	368	6
Gray sandy clay		368	372	4
Sandy clay w/course sand		372	386	8
Gray Dyerite fractured	✓	386	393	7
Gray clay		393	395	2

'94 FEB 16 AM 10:31
STATE ENGINEER

Date started 1-18, 1994
Date completed 1-25, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	12+		5

8. WELL CONSTRUCTION
Depth Drilled 395 Feet Depth Cased 395 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 5/8 Inches	166 Feet	395 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10	.188	165	395

Perforations:
Type perforation Factory Slotted T.C.
Size perforation 3 x 3/32
From 355 feet to 395 feet
From T.C. 315 feet to 355 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 198 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature warm °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W Phinnell (By driller performing actual drilling on site or contractor)
Date 1-25-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627