

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 44043
 Permit No. 09-107
 Basin 09-107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25459

1. OWNER RENE CARDINAL ADDRESS AT WELL LOCATION 2825 Hwy 208
 MAILING ADDRESS 20 PINION DRIVE GEN. STORE
WELLINGTON, NV 89444 WELLINGTON, NV 89444
 2. LOCATION NE 1/4 SW 1/4 Sec. 2 T. 10 S. R. 23 E LYON County
 PERMIT NO. 59-173 10-641-12 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL W/SM ROCK		0	5	
SM GRAVELS		5	20	
HARD ROCK SM GRVLS		20	45	
LEM. SM. GRAVELS		45	75	
MED GRVLS W/SIDE SAND	WB	75	100	

94 MAR -9 APR 51

8. WELL CONSTRUCTION
 Depth Drilled 100 Feet Depth Cased 100 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 100 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>	<u>1</u>	<u>1.88</u>	<u>0</u>	<u>100</u>

Perforations:
 Type perforation FACTORY
 Size perforation 3/32" x 3"
 From 50 feet to 100 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50" Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 100 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow 25 G.P.M. P.S.I.
 Water temperature WARM 79 °F Quality GOOD

Date started 1-29, 19 94
 Date completed 1-31, 19 94

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>3 1/2 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address P.O. BOX 92 Contractor
SMITH, NV 89430
 Nevada contractor's license number 32166
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 718T
 Division of Water Resources, the on-site driller.
 Signed Ed Miller
 By driller performing actual drilling on site or contractor
 Date 2 3 93