WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44070
Permit No.
Basin 4-6

NOTICE OF INTENT NO. 10351

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO NEVADA 89801

ADDRESS AT WELL LOCATION
BARRIK GOLDSTRIKE MINE

2. LOCATION SE ¼ NW ¼ Sec. 5 T 35 N ~~S~~ R 49 E EUREKA County
PERMIT NO. UIC NEV 93209 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVELAND CLAY		60	210	150
FRACTURED ROCK & CLAY		210	280	70
HARD ROCK & CLAY		280	290	70
GRAVEL & CLAY		290	330	40
BROWN ROCK & CLAY		330	360	30
CLAY		360	465	105
ROCK & CLAY		465	590	125
BROWN & GREYISH ROCK		590	640	50
HARD BLASK & BOWNISH ROCK		715	830	115
BROWN ROCK & CLAY		830	970	140
HARD BROWN ROCK		970	1040	70
FRACTURED BROWN ROCK		1040	1130	90
HARD BROWN ROCK		1130	1214	84

Date started DECEMBER 1, 1993
Date completed DECEMBER 19, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1214 Feet Depth Cased 1200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
46 Inches	0 Feet	40 Feet
32 Inches	40 Feet	350 Feet
29 Inches	350 Feet	1214 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	159	.375	0	40
32	127	.375	0	350
20	66	.375	0	560

Perforations:
Type perforation LOUVARD
Size perforation .125
From 560 feet to 1200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 518
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 518 feet to 1214 feet

9. WATER LEVEL
Static water level 240 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 70 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1800
Signed Victor Hernandez (By driller performing actual drilling on site or contractor)
Date March 30, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627