PPW-35

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44075
Permit No.
Basin 41-61

NOTICE OF INTENT NO. 26417

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NW ¼ NW ¼ Sec. 30 T 36 X N/S R 50 E EUREKA County
PERMIT NO. 55146 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAY GREEN DIORITE		0	20	20
GRAY GREEN DIORITE	CLAY	20	40	20
DIORITE CLAY PYRITE		40	60	20
DIORITE QUARTZ		60	80	20
DIORITE GRAY CLAY		80	160	80
DIORITE GRAY CLAY	TRACE	160	240	80
HARD DIORITE	TRACE	240	300	60
FRACTURED DIORITE	TRACE	300	310	10

Date started MARCH 17, 1994
Date completed MARCH 19, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 310 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12-1/4 Inches		0 Feet	20 Feet
7-7/8 Inches		20 Feet	310 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	247	.322	0	20
4	18	SCH 80	0	230

Perforations:
Type perforation SLOTTED
Size perforation 1/8
From 230 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 310 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 56 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1717
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-24-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627