WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44082
Permit No.
Basin 6-85

NOTICE OF INTENT NO. 21672

1. OWNER WALT WEAVER
MAILING ADDRESS 45 Palm Springs Crt.
Sparks, NV 89436

ADDRESS AT WELL LOCATION 370 Descanso
Sparks, NV 89436

2. LOCATION SW ¼ SW ¼ Sec. 31 T. 21N N/S R. 20 E. Washoe County
PERMIT NO. 4970 (Issued by Water Resources) 76-2 (Parcel No.) Spanish Springs (Subdivision Name) Wa. Co. Permit # 4970

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay		1	9	8
White clay w/gravels		9	17	8
Green clay		17	20	3
Brown clay		20	22	2
Green volcanic clay		22	79	57
Soft zone(NO WATER)		79	81	2
Gray volcanic rock		81	105	24
Black volcanic rock		105	139	34
Green volcanic rock (hard)		139	158	19
Fracture (NO WATER)		158	159	1
Green hard volcanic rock		159	255	96
Small fracture with hard volcanic rock		255	273	18
Green hard volcanic rock		273	331	58
Fracture	X	331	360	29
Hard volcanic rock		360	375	15

Date started 3-16-94, 19
Date completed 3-21-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 375 Feet Depth Cased 375 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	375 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	375

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 327 feet to 367 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 375 feet

9. WATER LEVEL
Static water level 280 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 22, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627