washoe # 004832

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK 28 HAC

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44085
Permit No.
Basin 6-84

NOTICE OF INTENT NO. 25236

1. OWNER Pam Egron
MAILING ADDRESS 1245 ZEPHYR WAY Sparks NV 89431
ADDRESS AT WELL LOCATION ~~500~~ Iron wood Road Palimino Valley NV 89431

2. LOCATION NE ¼ NE ¼ Sec. 20 T. 22 N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-220-88 (Parcel No.) Palomino V. Unit 7 20.21.1, par. 1 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
decomposed granite		0	90	90
DG + rocks		90	185	95
gray clay	x	185	187	3
hard granite		187	205	18
white granite		205	283	78
white + green clay		283	285	2
gray + green clay		285	300	15
gray clay + greenish white decomposed granite		300	323	23
Hard Granite		323	360	37
black Granite		360	362	2
white fractured DG		362	420	58
black + white soap stone Granite		420	423	3
white fractured DG		423	454	31
black Granite		454	463	9
white soft DG		463	474	11
white hard DG		474	490	16
white soft DG + Talc	x	490	500	10
white fractured DG	x	500	505	5

Date started 11 10, 1973
Date completed 3 19, 1974

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	150	3

8. WELL CONSTRUCTION
Depth Drilled 505 Feet Depth Cased 505 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10½ Inches		0 Feet	70 Feet
6 Inches		70 Feet	505 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	325
5		188	325	505

Perforations:
Type perforation factory Slotted
Size perforation 3/32
From 485 feet to 505 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 70 ft.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 250 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sep Miller (Contractor)
Address P.O. 92 (Contractor)
Smith NV 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1806
Signed (By driller performing actual drilling on site or contractor)
Date 3/19/94

(Rev. 3 91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627