WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44088
Permit No.
Basin 6-8

NOTICE OF INTENT NO. 24400

1. OWNER MICHAEL BROWNING
MAILING ADDRESS 5515 Wedekind Road
Sparks, NV 89431

ADDRESS AT WELL LOCATION 11520 Campo Rico Lane
Sparks, NV 89436

2. LOCATION SW ¼ NE ¼ Sec. 26 T 21N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 76-360-630 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	3	2
Soft sand		3	16	13
Brown clay		16	63	47
Soft zone (no water)		63	67	4
Brown sandy clay		67	88	21
Brown sandy clay		88	110	22
Brown sand	X	110	119	9
Brown clay		119	127	8
Brown sand	X	127	139	12
Brown clay		139	143	4
Brown sand	X	143	146	3
Brown soft clay		146	150	6

Date started 3-15-94, 19
Date completed 3-16-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10	Inches	0 Feet	50 Feet
8 5/8	Inches	50 Feet	150 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	150

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 102 feet to 142 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. 20 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 23, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627