

OFFICE USE ONLY
 Log No. 44124
 Permit No. 7
 Basin 9-108

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 3078

PRINT OR TYPE ONLY

1. OWNER Bob Chambers ADDRESS AT WELL LOCATION 42 Bybee Yerington NV 89497
 MAILING ADDRESS 3622 Glenwood Ave Redwood City, CA 94062

2. LOCATION NW 1/4 Sec. 25 T. 14 N. R. 26 E. Lyon County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Butters coarse gravel		95	110	15'
gravel & sand	X	110	120	10'
Boulders		120	122	2'
gravel & sand	X	122	127	5'
Boulders		127	135	8'
gravel & sand	X	135	148	13'
Coarse gravel	X	148	155	7'
Sand & gravel		155	160	5'
Boulders		160	170	10'

8. WELL CONSTRUCTION
 Diameter hole 10" inches Total depth 170 feet
 Casing record 6"
 Weight per foot 12.92 Thickness 188

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>170</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Metal plate between 10" & 6" casing
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 170 feet to 95 feet
 Perforations:
 Type perforation mill slots
 Size perforation 3" X 3/32"
 From 110 feet to 156 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Inland Pacific Drilling Co Inc Contractor
 Address P.O. Box 831 Yerington NV 89497 Contractor
 Nevada contractor's license number 0036582
 Nevada contractor's drillers number 1221
 Nevada driller's license number 1221 Actual Driller
 Signed Joel W. Brown Contractor
 Date March 16 1994

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	<u>15</u>	<u>1'</u>	<u>12</u>

BAILER TEST
 G.P.M. 20 Draw down 0 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours