


in Book

OFFICE USE ONLY
 Log No. 44133
 Permit No. _____
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 11819

1. OWNER Leonard J. & Alice Rodowick ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION SE 1/4 SW 1/4 Sec 27 T 19-S N/S R 53 E Nye County _____
 PERMIT NO. _____ File # 158730 Recorded 4-2-86
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface (lg rock & Gravel)		0	18	18
Rocks & Gravel				
Embedded in Clay		18	92	74
Reddish Clay		92	152	60
Gravel	x	152	158	6
Brown Clay		158	220	62
Gravel	x	220	224	4
Brown Clay		224	250	30
Soft Sandy Clay	x	250	256	6
Brown Clay		256	300	44

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	<u>18 lbs.</u>	<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:
 Type perforation Torch Cut
 Size perforation 4 in Width 8 in long
 From 200 feet to 220 feet
 From 240 feet to 260 feet
 From 280 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 300 feet

9. WATER LEVEL
 Static water level 106 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Contractor
 Address HCR 77 Box 36525 Contractor

Nevada contractor's license number 7484 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
 Signed Charles Nyberg
 By driller performing actual drilling on site or contractor
 Date 3-20-94



Date started March 10, 1994
 Date completed March 18, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>4</u>	<u>1/4</u>

RECEIVED
 MAR 29 1994
 Div. of Water Resources
 Branch Office Las Vegas, NV