WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44138
Permit No.
Basin 142

NOTICE OF INTENT NO. 1817

1. OWNER Stan & Mary Braithwaite
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 34 T. 19-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. 28 Subdivision Name Gerald Martin Subdivision

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown Clay		4	16	12
Clay/Small Gravel		16	44	28
Hard Shale		44	50	6
Brown Clay		50	68	18
Clay/Large Gravel		68	76	8
Soft Brown Clay	x	76	98	22
Hard Lime		98	108	10
Soft Brown Clay	x	108	146	38
Hard Lime		146	152	8
Brown Clay	x	152	186	34
Hard Lime		186	194	8
Brown Clay		194	200	6

RECEIVED
MAR 29 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Feb. 21, 1994
Date completed Feb. 23, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	200 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18 lbs.	.188	0	200

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in long
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date 3-5-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627