WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. T 44290
Permit No.
Basin 076

NOTICE OF INTENT NO. 26749

1. OWNER Lee Hill
MAILING ADDRESS 1925-95 South
Yerington, Nevada

ADDRESS AT WELL LOCATION 1925-95 South
Yerington, Nevada

2. LOCATION SE ¼ NE ¼ Sec. 36 T. 20 N/S R. 24 E. Lyon County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. Tiger Field (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Gravels		3	30	27
Brown Clay		30	63	33
Tan clay with Some Gravel		63	118	55
Gravels And boulder	✓	118	152	34
Brown Clay		152	175	23
Tan and Brown Clay		175	235	60
Brown Clay with Some Gravels Streks	✓	235	260	25

Date started 4-1, 1994
Date completed 4-6, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For About 2 Hours And Produced About 30 Gallons 4 min.		

8. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
11¼	0	260

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	3/16	+1	260

Perforations:
Type perforation Air Pert
Size perforation ¼ x 1 x 20 x 5 Rows
From 180 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 260 feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling (Contractor)
Address P.O. Box 599 (Contractor)
Silver Springs, NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 003,841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed (By driller performing actual drilling on site or contractor)
Date 4-20-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627