WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44294
Permit No.
Basin 84

NOTICE OF INTENT NO. 24403

1. OWNER PHILIP & DONDRA METSCHER
MAILING ADDRESS P.O. Box 328
Tonapah, NV 89049

ADDRESS AT WELL LOCATION
Rangeland Road
Reno, NV 89510

2. LOCATION SE ¼ SE ¼ Sec. 26 T 23N N/S R 20 E Washoe County
PERMIT NO. (Issued by Water Resources) 076-210-10 (Parcel No.) Palomino Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	6	5
Fine sand		6	16	10
Coarse sand with streaks of brown sands		16	32	16
Fine sand		32	36	4
Brown clay with streaks of sand		36	82	46
Brown clay		82	103	21
Brown sandy clay		103	114	11
Brown clay		114	148	34
Coarse sands	X	148	166	18
Brown clay		166	170	4
Med sand	X	170	206	36
Brown clay		206	215	9

Date started 4-18-94, 19
Date completed 4-20-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 215 Feet Depth Cased 215 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	215 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	215

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 155 feet to 175 feet
From 185 feet to 205 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 215 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow G.P.M. 40 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O.BOX 12370 (Contractor)
RENO, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (Driller performing actual drilling on site or contractor)
Date April 20, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627