WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44896
Permit No.
Basin 8-88

NOTICE OF INTENT NO. 25291

1. OWNER BINNEWEG Construction
MAILING ADDRESS Box 18166 Reno, NV 89511
ADDRESS AT WELL LOCATION 16240 Mount Rose Hwy Reno, NV

2. LOCATION NW ¼ SE ¼ Sec. 34 T. 18 N/S R. 19 E. Washoe County
PERMIT NO. ____ Issued by Water Resources | 49-090-02 Parcel No. | Callahan Ranch Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders & D.G., Hard		0	10	10
Dark, Hard Granite		10	100	90
Granite, light color w/ Clay seams		100	218	118
Fractured granite w/ Clay seams		218	265	47
Fractured granite w/ H_2O	xx	265	300	35
Blue to Black Granite, Hard, w/ fractures		300	400	100
Carrying water				
Major water courses from 370-390'	xx			
T.D. 400 ft				
16-18 GPM from 320 feet				

Date started 3/19, 1994
Date completed 3/26, 1994

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed with 352 psi 750 C.F. Air for 4 hours		

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	60 Feet
9 7/8 Inches	60 Feet	400 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.8	.188	+2	400

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32" x 3"
From 200 feet to 220 feet
From 260 feet to 280 feet
From 380 feet to 400 feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 400 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co Contractor
Address Carson City, NV 89701 Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1450
Signed [signature] By driller performing actual drilling on site or contractor
Date March 28, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627