WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44309
Permit No.
Basin 89

NOTICE OF INTENT NO. 26807

1. OWNER Tim Knittan
MAILING ADDRESS 480 Duckhill Rd. Carson City 89704
ADDRESS AT WELL LOCATION 480 Duckhill Rd Carson City NV. 89704

2. LOCATION SW ¼ NW ¼ Sec. 36 T. 16 N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources 055-270-06 Parcel No. None Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
DG Sands & Gravels		3	64	61
Coarse DG Sands		64	114	50
Hard DG Coarse		114	139	25
Soft DG Sands Rusty Color		139	245	106
Blue Granite (Hard) Black & White		245	265	20
Broken Blue Granite (Hard) Broken Chips	XXX	265	300	35

Date started 4-19, 19 94
Date completed 4-21, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-17	75'	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 300' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11¼ Inches		0 Feet	55 Feet
10¾ Inches		55 Feet	300' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	300'

Perforations:
Type perforation Mill Slot
Size perforation 3 X 32
From 260 feet to 300' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 300' feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. 15-17 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name
Contractor A & H Pump CO
Address 5551 Hwy 50 East #
Contractor Carson City, Nevada 89
53-0459 - 883-
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 4-22-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627