VEW #2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44312
Permit No.
Basin 09

NOTICE OF INTENT NO. 26664

1. OWNER Gas-A-Mart Mark Michelsen
MAILING ADDRESS P.O. Box 2010 Stateline, NV 89449
ADDRESS AT WELL LOCATION Gas-A-Mart Station Kingsbury Rd Stateline, NV

2. LOCATION NW ¼ NW ¼ Sec. 26 T. 13 N/S R. 18 E. Douglas County
PERMIT NO. M/O 780 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	2	2
Granite		2	40	38

Hole sand packed with #8-12 silica sand
3' chip bentonite seal was placed from 4-1/2' to 7-1/2'
Monitor well monument cemented in flush with surface

Date started April 15, 19 94
Date completed April 16, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	40 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" ID	PVC	SCH 40	-3"	40

Perforations:
Type perforation slots
Size perforation .020
From 10 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 4-1/2'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 7-1/2' feet to 40 feet

9. WATER LEVEL
Static water level N/A feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
Signed Dale C. Nelson (By driller performing actual drilling on site or contractor)
Date 4-21-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627